



Notice of Revised Pedernales Electric Cooperative Specifications Posted September 22, 2022

Residential and Commercial 320 Amp Meter Loop Specifications

- Various Pages
 - Added the following note: *SEE PAGE 8 FOR GROUNDING AND BONDING DETAIL.*
 - Removed the word *RIGID* from callout notes regarding nipples between panels, meter sockets, and troughs.
 - Added drawing detail showing ground wire routing through nipples between panels, meter sockets, and troughs.
- Page 3
 - Added the word *continuously* to *Pipe Nipple Connections* Note 3.
- Pages 11 & 12
 - Moved 18" maximum dimension between weatherhead and eye bolt to correct position.

Note: *The summaries listed here and in previous notices primarily include revisions considered technically significant to these specifications. Edits considered technically insignificant may not be listed.*